

Data for the Month:

June 2016

Data published:

July 2016

Basin ID	Date of Discharge	pH	Oil and Grease (Visibility)	TSS (mg/L)	*NTU	Comment
TB1252L	9/06/2016	7.8	NV	28	34	#Lab sample collected
PB624R	9/06/2016	7.2	NV		18	
PB135L	9/06/2016	7.3	NV		30	
PB82L	9/06/2016	7.8	NV		60	
TB512R	10/06/2016	7.7	NV		30	
PB351R	10/06/2016	7.8	NV		15	
TB369R	10/06/2016	7.5	NV		<20	
TB680L	10/06/2016	7.4	NV		40	
TB820L	10/06/2016	6.6	NV		50	
TB210R	11/06/2016	8.3	NV		60	
KTR Office	11/06/2016	6.8	NV	2	15	#Lab sample collected
TB278R	11/06/2016	8	NV		50	
PB838L	11/06/2016	6.7	NV		15	
Hawthorne Pad	11/06/2016	7.4	NV		15	
TB1079L	11/06/2016	6.8	NV		60	
TB1112L	11/06/2016	6.6	NV		55	
PB135L	11/06/2016	6.6	NV		40	
TB949R	14/06/2016	7.9	NV		42	
PB624	15/06/2016	7.73	NV		60	
PB571R	15/06/2016	7.4	NV		55	
PB466R	15/06/2016	8.3	NV		23	
PB27L	16/06/2016	8	NV		60	
TB Batch Plant CH3700	16/06/2016	7.9	NV		35	
PB292R	17/06/2016	8.3	NV	9	38	#Lab sample collected
TB1037L	18/06/2016	6.8	NV		52	
PB38L	18/06/2016	7.8	NV		50	
TB749L	18/06/2016	7.9	NV		20	
Hawthorne Pad	18/06/2016	6.9	NV		25	
TB512R	20/06/2016	6.8	NV		60	
Hawthorne Pad	20/06/2016	6.8	NV		58	
PB135R	20/06/2016	6.8	NV		58	
TB610R	20/06/2016	6.9	NV		35	
TB610R	21/06/2016	7.7	NV		18	
PB292R	21/06/2016	7.7	NV		28	
PB351R	21/06/2016	7.7	NV	9	20	#Lab sample collected
PB466R	21/06/2016	7.6	NV		42	
Hawthorne Pad	21/06/2016	7.7	NV		26	
TB1252L	22/06/2016	8	NV		20	
PB82L	22/06/2016	8.3	NV		60	
PB82L	23/06/2016	8.2	NV		58	
TB7200R	23/06/2016	8.3	NV		35	
TB895L	23/06/2016	8	NV		25	

Data for the Month: June 2016

Data published: July 2016

Basin ID	Date of Discharge	pH	Oil and Grease (Visibility)	TSS (mg/L)	*NTU	Comment
PB27L	23/06/2016	8	NV		55	
PB27L	24/06/2016	7.9	NV		47	
PB38L	24/06/2016	8.2	NV		53	
PB135L	24/06/2016	8.2	NV		38	
TB749L	24/06/2016	7.4	NV		58	
TB Batch Plant CH3700	24/06/2016	6.8	NV	42	55	#Lab sample collected
KTR Office	24/06/2016	7.6	NV		50	
PB838L	24/06/2016	7.5	NV		45	
TB1079R	24/06/2016	6.9	NV		<20	
TB1037L	25/06/2016	7	NV		40	
TB512R	25/06/2016	7.5	NV		50	
PB163L	25/06/2016	7.4	NV		30	
TB278R	25/06/2016	7.1	NV		40	
TB1112L	25/06/2016	7.4	NV		<20	
PB479R	27/06/2016	6.9	NV		40	
PB624	27/06/2016	7.1	NV		25	
TB1037L	27/06/2016	6.9	NV		40	
TB1227L	27/06/2016	6.8	NV	9	<20	#Lab sample collected
TB Batch Plant CH3700	28/06/2016	8	NV		30	
TB278R	29/06/2016	7.1	NV		47	
Batch Plant	29/06/2016	7.8	NV		35	
TB512R	29/06/2016	7.5	NV		25	
PB571R	29/06/2016	7.4	NV		40	
PB1032R	29/06/2016	7.5	NV		55	
Hawthorne House	29/06/2016	7.1	NV		<20	

Pollutant	TSS	*NTU	pH	Oil and Grease
Concentration Limit	50	60	6.5 – 8.5	Not visible

mg/L = milligrams per litre N/A = Not applicable NV = Not visible NC = Non-Conformance ND = No Discharge DNS = Did Not Sample TSS = Total Suspended Solids (mg/L)	*NTU = Nephelometric Turbidity Units A correlation between TSS and NTU has been established for the site. NTU reading of 60 has been adopted to ensure samples have a TSS of below 50mg/L. #1/10 Basin discharges to be lab tested for TSS; for correlation verification.
---	--