

Data for the Month:

September 2016

Data published:

October 2016

| Basin ID | Date of Discharge | pH (unit) | Oil and Grease (Visibility) | TSS (mg/L) | *NTU | Comment |
|-----------------------|-------------------|-----------|-----------------------------|------------|------|-----------------------|
| TB Batch Plant CH3700 | 5/09/2016 | 8.5 | NV | 2 | 24 | #Lab sample collected |
| PB466R | 5/09/2016 | 8.5 | NV | 2 | 24 | #Lab sample collected |
| TB949R | 5/09/2016 | 6.7 | NV | | 45 | |
| PB838L | 12/09/2016 | 6.8 | NV | | 20 | |
| TB512R | 12/09/2016 | 7 | NV | 8 | 24 | #Lab sample collected |
| TB Batch Plant CH3700 | 12/09/2016 | 8.3 | NV | 3 | 35 | #Lab sample collected |
| PB571R | 12/09/2016 | 7.9 | NV | 8 | 24 | #Lab sample collected |
| PB572L | 12/09/2016 | 7.2 | NV | 11 | 24 | #Lab sample collected |
| PB624R | 12/09/2016 | 6.8 | NV | | 18 | |
| TB1252L | 13/09/2016 | 6.8 | NV | | 18 | |
| TB610R | 13/09/2016 | 7.9 | NV | 16 | 24 | #Lab sample collected |
| TB1037L | 13/09/2016 | 6.85 | NV | | 30 | |
| TB1112L | 14/09/2016 | 6 | NV | | 45 | |
| TB1112L | 19/09/2016 | 7 | NV | | 35 | |
| TB949R | 19/09/2016 | 7.4 | NV | | 45 | |
| TB1322L | 20/09/2016 | 7.9 | NV | | 20 | |
| TB512R | 27/09/2016 | 8.3 | NV | 7 | 24 | #Lab sample collected |

| Pollutant | TSS | *NTU | pH | Oil and Grease |
|---------------------|-----|------|-----------|----------------|
| Concentration Limit | 50 | 60 | 6.5 – 8.5 | Not visible |

| | |
|---|--|
| mg/L = milligrams per litre N/A = Not applicable NV = Not visible NC = Non-Conformance ND = No Discharge DNS = Did Not Sample TSS = Total Suspended Solids (mg/L) | *NTU = Nephelometric Turbidity Units A correlation between TSS and NTU has been established for the site. NTU reading of 60 has been adopted to ensure samples have a TSS of below 50mg/L. #1/10 Basin discharges to be lab tested for TSS; for correlation verification. |
|---|--|