

Data for the Month:

January 2017

Data published:

February 2017

Basin ID	Date of Discharge	pH	Oil and Grease (Visibility)	TSS (mg/L)	*NTU	Comment
<b>TB Batch Plant CH3700</b>	9/01/2017	7.3	NV		30	
<b>TB512R</b>	9/01/2017	6.9	NV		20	
<b>PB572L</b>	9/01/2017	7.7	NV	8	20	#Lab sample collected
<b>TB1227L</b>	9/01/2017	7.5	NV		20	
<b>Hawthorne Pad</b>	9/01/2017	7.9	NV		17	
<b>KTR stockpile</b>	10/01/2017	6.9	NV		20	
<b>PB1252L</b>	10/01/2017	6.7	NV		40	
<b>TB278R</b>	10/01/2017	7.6	NV		20	
<b>PB135L</b>	11/01/2017	6.7	NV		40	
<b>TB1037L</b>	11/01/2017	7.8	NV	18	55	#Lab sample collected
<b>TB1112L</b>	11/01/2017	6.9	NV		35	
<b>PB624R</b>	11/01/2017	8	NV		<60	
<b>Hawthorne Pad</b>	11/01/2017	8	NV		<60	
<b>TB720R</b>	11/01/2017	7.9	NV		27	
<b>TB680L</b>	11/01/2017	7.5	NV		32	
<b>PB838L</b>	11/01/2017	6.8	NV		20	
<b>TB895R</b>	11/01/2017	7.5	NV		25	
<b>TB730R</b>	11/01/2017	7.5	NV		<60	
<b>TB949R</b>	14/01/2017	6.8	NV	44	<60	#Lab sample collected
<b>TB1112L</b>	16/01/2017	6.9	NV		50	
<b>TB278R</b>	17/01/2017	7.8	NV		35	
<b>PB479R</b>	17/01/2017	7.3	NV		45	
<b>TB Batch Plant CH3700</b>	18/01/2017	7.8	NV		50	
<b>KTR stockpile</b>	18/01/2017	8	NV		50	
<b>KTR Office</b>	19/01/2017	8.3	NV		55	
<b>TB1112L</b>	23/01/2017	7	NV		40	
<b>PB351R</b>	24/01/2017	8.4	NV	12	24	#Lab sample collected

Pollutant	TSS	*NTU	pH	Oil and Grease
<b>Concentration Limit</b>	50	60	6.5 – 8.5	Not visible

mg/L = milligrams per litre  
 N/A = Not applicable  
 NV = Not visible  
 NC = Non-Conformance  
 ND = No Discharge  
 DNS = Did Not Sample  
 TSS = Total Suspended Solids (mg/L)

\*NTU = Nephelometric Turbidity Units  
 A correlation between TSS and NTU has been established for the site.  
 NTU reading of 60 has been adopted to ensure samples have a TSS of below 50mg/L.  
 #1/10 Basin discharges to be lab tested for TSS; for correlation verification.