

Data for the Month:

February 2017

Data published:

March 2017

Basin ID	Date of Discharge	pH	Oil and Grease (Visibility)	TSS (mg/L)	*NTU	Comment
TB1037L	02/02/2017	6.5	NV		25	
TB Batch Plant	15/02/2017	8.3	NV		45	
PB1252L	21/02/2017	6.7	NV		55	
TB1112L	24/02/2017	6.7	NV		35	
KTR Office	24/02/2017	8.4	NV		24	
TB949R	25/02/2017	7	NV		35	

Pollutant	TSS	*NTU	pH	Oil and Grease
Concentration Limit	50	60	6.5 – 8.5	Not visible

mg/L = milligrams per litre N/A = Not applicable NV = Not visible NC = Non-Conformance ND = No Discharge DNS = Did Not Sample TSS = Total Suspended Solids (mg/L)	*NTU = Nephelometric Turbidity Units A correlation between TSS and NTU has been established for the site. NTU reading of 60 has been adopted to ensure samples have a TSS of below 50mg/L.  #1/10 Basin discharges to be lab tested for TSS; for correlation verification.
---	--