

Data for the Month: April 2015

Data published: May 2015

Basin ID	Approx. Chainage	Date of Discharge	*NTU	pH (unit)	Oil and Grease (Visibility)	(Lab) Total Suspended Solids (mg/L)	Comment
Railway Terrace North		2/04/2015	7.2	7.4	No		
TB 2.80		8/04/2015	11.8	7.8	No		
Culvert 4200		8/04/2015	27.3	8.1	No		
TB 2.43		8/04/2015	37.4	7.4	No	5	
Boundary Road Sump		10/04/2015	18.2	6.9	No		
Railway Terrace North		10/04/2015	8.7	6.8	No		
Railway Terrace South		10/04/2015	37.6	8.1	No		
Culvert 2515		10/04/2015	18	8.5	No		
Railway Terrace North		13/04/2015	4.3	7.2	No		
TB 5.50		14/04/2015	37	7.8	No		
Railway Terrace South		15/04/2015	25.8	8.2	No		
Sump 2.80		15/04/2015	9.8	7.9	No		
Culvert 4200		15/04/2015	10.1	8.2	No		
Culvert 4200		15/04/2015	14.8	8	No		
Railway Terrace North		16/04/2015	18.2	8.4	No		
Sump 2.80		24/04/2015	17	6.6	No		
Boundary Road Sump		24/04/2015	22.9	6.6	No		
Railway Terrace North		24/04/2015	8.9	6.6	No		

Basin ID	Approx. Chainage	Date of Discharge	*NTU	pH (unit)	Oil and Grease (Visibility)	(Lab) Total Suspended Solids (mg/L)	Comment
Bridge to Veron Holding Cell 1		24/04/2015	38.9	6.7	No		
Sump 2.80		27/04/2015	5.7	6.6	No		
Boundary Road Sump		27/04/2015	15	6.7	No		
Endeavour Energy Sump		27/04/2015	38	6.7	No		
Culvert 4200		27/04/2015			No		
Culvert 4200		27/04/2015	15.7	6.7	No		
Bridge to Veron Holding Cell 2		27/04/2015	12	7.6	No		
Railway Terrace South		27/04/2015	39	7.5	No		
Hambledon Road near Intersection		28/04/2015	23.5	7.2	No		
Railway Terrace North Pit		28/04/2015	33.3	8	No		
Railway Terrace North		28/04/2015	31.9	6.9	No		
Railway Terrace South		30/04/2015	34.2	8.2	No		

Pollutant	TSS	*NTU	pH	Oil and Grease
Concentration Limit	50	40	6.5 – 8.5	Not visible

mg/L = milligrams per litre N/A = Not applicable NV = Not visible ND = No Discharge DNS = Did Not Sample	TSS = Total Suspended Solids (mg/L) *NTU = Nephelometric Turbidity Units <i>A correlation graph between TSS and NTU has been established for the site. Using a 50% safety factor, an NTU reading of 40 has been adopted to ensure samples have a TSS of below 50mg/L.</i>
--	---

OHL York Joint Venture | Schofields Road Upgrade Stage 2

37 Schofields Road, Schofields NSW 2762 | PO Box 6275 Rouse Hill Town Centre NSW 2155
 For more information or enquiries please email dmalysiak@ohlaustralia.com