



Data for the Month: July 2015

Data published: August 2015

Basin ID	Approx. Chainage	Date of Discharge	*NTU	pH (unit)	Oil and Grease (Visibility)	(Lab) Total Suspended Solids (mg/L)	Comment
First Ponds Sump	CH2800	14.07.2015	32.8	7.8	None visible		Discharged to TB 2.80
TB 2.80	CH2800	14.07.2015	9.8	8.5	None visible		
TB 5.50	CH5500	14.07.2015	23.8	8.0	None visible		
Veron Rd Swale	CH5500	27.07.2015	35.3	8.5	None visible		Discharged to TB 5.50
TB 2.80	CH2800	27.07.2015	6.8	8.5	None visible		
First Ponds sump	CH2800	27.07.2015	27.3	7.5	None visible		Discharge to TB 2.80

Pollutant	TSS	*NTU	pH	Oil and Grease
Concentration Limit	50	40	6.5 – 8.5	Not visible

mg/L = milligrams per litre N/A = Not applicable NV = Not visible ND = No Discharge DNS = Did Not Sample	TSS = Total Suspended Solids (mg/L) *NTU = Nephelometric Turbidity Units A correlation graph between TSS and NTU has been established for the site. Using a 50% safety factor, an NTU reading of 40 has been adopted to ensure samples have a TSS of below 50mg/L.
--	--